

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**


No.F6/DFS/MS/2022/ School/NDZ/ 109

Dated: 3./2../2022

**FIRE SAFETY CERTIFICATE**

Certified that **Mater Dei School** located at **Tilak Lane, New Delhi** comprises of Ground + **03 upper floor** owned/occupied by Mater Dei School was earlier granted FSC by this department vide letter no. **F6/DFS/MS/2018/School/NDZ/2521** dated **12/11/2018**. Now, the premises was re-inspected by the officers concerned of this department on 27-01-2022 in the presence of Mr. Satlin (Admn. Officer) and found that the said school building have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of class **Group B "Educational Building"** with effect from ...3../2../.....2022 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Issued on 3./2../2022..... at New Delhi by.



(Dr. S.K. Tomar)  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Admin. Officer,  
Mater Dei School at Tilak Lane, New Delhi.
2. Director of Education, Govt. of NCT, Delhi.


**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the fire safety arrangements provided there in shall be maintained in good working condition at all time.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Basement shall be used as per NBC/BBL 1983.
6. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
7. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
8. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry.



DR. PRAVE  
PRESIDENT/VICE-PRESIDENT

For Society of the Franciscan



Principal  
Mater Dei School  
Tilak Lane,  
New Delhi - 110001